

CALGARY FIRE

Page 1 of 6

FD 1328 (Jan 2018)

For tanks located within the City of Calgary, the Calgary Fire Department is the Authority Having Jurisdiction (AHJ). In accordance with Article 2.2.3.1. of Division "C" of the Alberta Fire Code 2014, Safety Codes Officers are permitted to review storage tank installation plans, drawings and specifications in a form acceptable to the AHJ in lieu of requiring the submission of 3 sets of engineered stamped drawings. This only applies to individual storage tanks located outdoors with a capacity not greater than 8,000 litres (including all compartments) and to tank installations with aggregate capacity not greater than 20,000 litres where all storage tanks and piping are aboveground and visible for inspection by the Safety Codes Officer. Plans, drawings and specifications for all storage tank system installations must include sufficient information to allow a Safety Codes officer to complete an examination that shows full compliance with the Alberta Fire Code. If the installation is deemed to be of a complex nature drawings may be required to bear the stamp and seal of a registered engineering professional authorized to practice in Alberta.

Applicant Information Applicant Name Email Address Company Phone # Fax # Mailing Address City Province Postal Code **Facility Information Facility Name Facility Address** Postal Code Contact Person **Phone Number** Type of Usage Will tanks be taken out of service ☐ Yes □No due to this installation? Number of existing Number of existing underground above ground tanks tanks

Form Approver: Deputy Chief Risk Management

ISC: Protected



CALGARY THE PRICE OF THE PRICE

FD 1328 (Jan 2018)

Owner Information			
Company			
Full Mailing Address			
Tank Installer Information (When ed approved individual is required to sup	quipment such as, but not limited to; piping, ervise the installation).	fittings, valves, or dispe	enser connections are made in the field an
Name of company performing tank installation			
Installer Phone Number		Name of Person Supervising the installation	
Installation Information			
This installation is		Proposed Install Date (YY/MM/DD)	
Are all tank system components including piping above ground? (Note: Dike liners are usually not visible)	☐ Yes ☐ No		
Have a minimum of two 40 BC fire extinguishers been installed?	☐ Yes ☐ No		
Are there any overhead Power lines?		Have all tanks been installed outdoors?	☐ Yes ☐ No

Form Approver: Deputy Chief Risk Management	Page 2 of 6
ISC: Protected	



CALGARY

FD 1328 (Jan 2018)

For the following section, complete one column per tank. If your tank has more than one compartment, complete one column for each compartment.

	Column 1	Column 2	Column 3	Column 4
Tank Number (list each tank separately; place each compartment in a new column)				
Compartment				
Tank capacity (in litres)				
Name of product being stored				
Tank ULC Construction Standard (can be found on a placard mounted on the tank exterior or from its manufacturer's spec sheet)				
If other, indicate specification				
Is the tank single walled or double walled?	☐ Single ☐ Double	☐ Single☐ Double	☐ Single ☐ Double	☐ Single☐ Double
Is the tank supported more than 300mm off the ground? (Does not apply to tank saddles/legs mounted by tank manufacturers)				
Tank distance to nearest property line (meters)				
Will tank fill pipes and vents be outdoors?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Describe how your tanks will be protected from collision (type of barriers, spacing and distance to tank)				
Distance to any propane or natural gas tanks				
Distance to nearest tank (meters)				
Distance to nearest building (meters)				
Will the tank be grounded? (required)	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Are all pipe openings above the normal tank product level? (required)				
Height of vent pipe discharge outlet above grade level				
If a used oil tank, does it have a fixed suction tube? (required)	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Form Approver: Deputy Chief Risk Management ISC: Protected				Page 3 of 6

Disclaimer: Any hardcopies and electronic copies outside of the published repository are considered uncontrolled.



ISC: Protected

SMALL TANK PERMIT APPLICATION

CALGARY FIRE

FD 1328 (Jan 2018)

Dispenser & Signage Information

Are there signs for emergency shutdown, no smoking & turn off ignition?	☐ Yes ☐ No
Is there signage identifying tank contents posted on two sides of the tank?	☐ Yes ☐ No
Is a dispenser connected to the tank?	☐ Yes ☐ No
Complete the following sections if you are dispensing product:	
Are there operating instructions for dispensing posted?	☐ Yes ☐ No
Distance of dispenser to building openings in meters	
Is there a storm drain within 6 m of any dispenser?	☐ Yes ☐ No
Indicate the distance to emergency shutdown devices from dispensing equipment (required)	
Are there signs indicating location of an emergency shutdown button?	☐ Yes ☐ No
Is all power buried for the fuel dispensing operation & emergency button?	☐ Yes ☐ No
If operating a self-serve retail facility, is there an intercom between the customer and inside employee?	☐ Yes ☐ No
Is there protection from spills when dispensing?	☐ Yes ☐ No
Is there a fuel mounted pump on top of the tank, or is piping used to connect it to a nearby dispenser?	☐ Yes ☐ No
Complete the following section if your pump is mounted on top of the tank:	
Provide the make and model of the dispensing equipment	
Complete the following section if your pump is connected to a nearby dispens	ser via piping:
Will there be an anti-siphon valve between the tank and any dispenser?	☐ Yes ☐ No
Is there any buried pipe?	☐ Yes ☐ No
Is aboveground piping made of steel?	☐ Yes ☐ No
Is the dispenser protected from collision or on an island higher than 100mm?	☐ Yes ☐ No
Form Approver: Deputy Chief Risk Management	Page 4 of 6

Disclaimer: Any hardcopies and electronic copies outside of the published repository are considered uncontrolled.





FD 1328 (Jan 2018)

Site Diagram:				
Prepare a diagram which clearly shows the location of storage tank(s) relative to streets, buildings, property lines, any dispensers, propane tanks, or any important features of the property. The diagram should be as close to scale as possible.				

Form Approver: Deputy Chief Risk Management

ISC: Protected

Page 5 of 6

Disclaimer: Any hardcopies and electronic copies outside of the published repository are considered uncontrolled.



CALGARY FIRE

FD 1328 (Jan 2018)

☐ Submit as a	separate attachment, the tank manufacturing specification	n sheet if available.	
☐ Submit as a separate attachment, photographs of tank installation (including front & side views) once installed.			
Verification: My signature confirms the information provided is complete and accurate to the best of my knowledge. I understand I am making an application to install a storage tank without the Alberta Fire Code requirement for engineered drawings prepared by a Professional Engineer. Further, by not retaining the services of a Professional Engineer I am assuming responsibility for any necessary alterations if an inspection by a Safety Codes Officer finds the installation is not in conformance with any requirement of the Alberta Fire Code.			
Name (print)		Phone Number	
Signature		Date (YY/MM/DD)	

The Permit Regulation for the province of Alberta came into effect April 1, 2008. The regulation mandates that a permit shall be applied for and issued for all petroleum storage tank installations, removals or alterations.

Small Aboveground Tank Installation Application Process:

- 1. Complete and submit the small tank permit application.
- 2. The application will be reviewed Fire Code compliance. If the application is complete a letter and permit will be issued. If it is not complete a deficiency letter will be issued requesting additional information prior to approval.
- 3. Once the application is complete and compliant with the Fire Code the applicant will be invoiced for the initial review and any subsequent reviews.
- 4. A permit to install shall also be issued to the applicant.
- 5. Contact 311 to have a Safety Codes Officer perform a physical inspection once the project is complete and prior to the tanks being filled or put into use. Any deficiencies will be forwarded to the applicant and subject to an additional inspection fee.
- 6. Once a final inspection has been completed and all deficiencies are cleared a letter of approval and certificate will be issued.

Form Approver: Deputy Chief Risk Management	Page 6 of 6
ISC: Protected	